

MG250S-II

NBC FILTER-VENTILATING SYSTEM



NBC filter






Device for the protection of people

- Usage:
- a) civil defence shelters, containers, field hospitals
 - b) van vehicles and other means of transport
 - c) health service - operation rooms, laboratories, ICU, (intensive care units), ambulance cars
 - d) sanatoriums, schools, public buildings, residences

Powerful filtration (0,0003 mm=0,3µm); NBC filter: chemical, radioactive, bacteriological contamination (allergens, pollens, organic solvents, acid vapours and gases, alkaline vapours and gases, formaldehyde vapours, mercuric vapours, poisonous gases).

Technical parameters

	MG250S-II
Air-flow rate	250 m ³ /hod at 20% filter contamination
Power Supply	a) 230 V / 50 Hz b) 12 V (battery, emergency source)
Weight	53 kg
Dimensions	570 x 550 x 750 mm
El. input	Pmax/min = 120 / 70 W
Sound level	45 dB (A)
• UV-C lamp	
• Visual checking	
• Beep	
• Back-up power supply UPS	



FEATURES

- Filtration efficiency 99,999% MPPS
- Independence on the central ventilating system
- Polluted filter signalling
- Safe storage
- Mechanical resistance acc. CSVN 09 105, Category N7
- High reliability acc. CSVN 01 105
- Climatic resistance acc. CSVN 09 0105
- Shielding IP 65
- El. Compatibility acc. EN 33 2000-6-61
- Efficiency shielding acc. MIL-STD IEEE 299; NSA 65

Certified ISO 9001 : 2000 by



Certification: Product authorisation No C5-05-0375 from 1.08.2005; EN 13779:05, EN 12100-2:04, EN 13053:02, EN ISO 4871:98, EN ISO 11204:97; 12 7010, 73 0872, EN 779+AC, CSN 12 4000, NV 81/1999 withing usage EN 60 204-1, NV 502/2000Sb., CSN 12 0017, ČSN EN 294, meet all features mentioned in the technical specifications and security requirements issued by Certifying company No 227, Prazska 810/16, Prague 10, CZ. Cataloguing No: 1673G, Product authorisation No 1060559; EN 60335; EN 55014; EN 61000 z 30. 6. 2006 issued by certification copany EZÚ, s. p. 171 02 Praha 8 – Troja, Pod Lisem 129, CZ; Notification authority No 1014



POHORELEC s.r.o., 533 32 Pardubice, Čepí 100, CZ
tel: +420 466 971 132, fax: +420 466 971 261
E-mail: ovz@pohorelec.cz, www.pohorelec.cz, www.nbcteam.cz